

| Outlet ID | SCHOOL | Outlet Location | Outlet Type | Notes | PPB |
|-------------|-------------|-----------------------------------|----------------------------|------------|----------|
| 180-567-EWC | 5-6-7 GRADE | IN WEST MAIN ENTRANCE | ELECTRIC WATER COOLER HIGH | 1st sample | <2.5ppb |
| 181-567-EWC | 5-6-7 GRADE | IN WEST MAIN ENTRANCE | ELECTRIC WATER COOLER LOW | 1st sample | <2.5ppb |
| 29-567-EWC | 5-6-7 GRADE | GYM | ELECTRIC WATER COOLER | 1st sample | <2.5ppb |
| 94-567-EWC | 5-6-7 GRADE | BATHROOM 623 ACROSS W208 LEFT | ELECTRIC WATER COOLER LOW | 1st sample | <2.5ppb |
| 144-567-EWC | 5-6-7 GRADE | BATHROOM 613 ACROSS FROM FJ1 | ELECTRIC WATER COOLER LOW | 1st sample | <2.5ppb |
| 152-567-DO | 5-6-7 GRADE | ROOM W177 | DRINKING OUTLET | 1st sample | <2.5ppb |
| 2-567-CF | 5-6-7 GRADE | E150 TO LEFT ON LEFT WALL | CLASSROOM FAUCET | 2nd sample | 50.1ppb |
| 8-567-CF | 5-6-7 GRADE | E134 LEFT OF DOOR | CLASSROOM FAUCET | 2nd sample | 35.5ppb |
| 41-567-CF | 5-6-7 GRADE | E236 WALL | CLASSROOM FAUCET | 2nd sample | 22.6ppb |
| 42-567-CF | 5-6-7 GRADE | E234 WALL | CLASSROOM FAUCET | 2nd sample | 23.3ppb |
| 81-567-KF | 5-6-7 GRADE | KITHEN UNDER EXHAUST HOOD | KITCHEN FAUCET 1 | 2nd sample | 36.2ppb |
| 82-567-KF | 5-6-7 GRADE | KITHEN UNDER EXHAUST HOOD | KITCHEN FAUCET 2 | 2nd sample | 13.7ppb |
| | | | | | |
| 9-HS-CF | HIGH SCHOOL | CUSTODIAL BREAKROOM | CLASSROOM FAUCET | 1st sample | <2.5ppb |
| 52-HS-EWC | HIGH SCHOOL | ELEVATOR LOBBY 1ST FLOOR D | Electric Water Cooler LOW | 2nd sample | <2.5ppb |
| 83-HS-CF | HIGH SCHOOL | ROOM 113 | CLASSROOM FAUCET | 2nd sample | 5.05ppb |
| 112-HS-F | HIGH SCHOOL | 11th GRADE OFF. WORK ROOM | FAUCET | 2nd sample | <2.5ppb |
| | | | | | |
| 32-8GC-IM | 8TH GRADE | TRAINER ROOM ACROSS FROM KITCHEN | ICE MACHINE | 1st sample | <2.5ppb |
| 33-8GC-F | 8TH GRADE | TRAINER ROOM ACROSS FROM KITCHEN | FAUCET | 1st sample | <2.5ppb |
| 6-8GC-KF | 8TH GRADE | KITCHEN DOUBLE STAINLESS | KITCHEN FAUCET | 2nd sample | 11.2ppb |
| 14-8GC-KF | 8TH GRADE | KITCHEN TRAY ROOM WALL MOUNT | KITCHEN FAUCET | 2nd sample | 41.3ppb |
| | | | | | |
| 14-SCE-CF | SPRING CITY | ROOM 11 KINDERGARTEN | CLASSROOM FAUCET LEFT | 2nd sample | 13.9ppb |
| | | | | | |
| 33-9GC-CF | 9TH GRADE | MUSIC ROOM 118 RIGHT SIDE OF DOOR | CLASSROOM FAUCET | 2nd sample | 26.9ppb |
| 34-9GC-F | 9TH GRADE | STAGE | FAUCET | 2nd sample | 14.4ppb |
| 40-9GC-CF | 9TH GRADE | ROOM 205 RIGHT OF MAIN DOOR | CLASSROOM FAUCET | 2nd sample | 22.11ppb |

| | | | | | |
|------------|------------|-----------------------------------|-----------------------|------------|----------|
| 6-ROY-DO | ROYERSFORD | ROOM 6 | DRINKING OUTLET | 2nd sample | 10ppb |
| 12-ROY-DO | ROYERSFORD | ROOM 12 | DRINKING OUTLET | 2nd sample | 10.8ppb |
| 17-ROY-F | ROYERSFORD | STAGE | FAUCET | 2nd sample | 90.05ppb |
| 26-ROY-F | ROYERSFORD | LIBRARY TV STUDIO | FAUCET | 2nd sample | 108ppb.9 |
| 30-ROY-KF | ROYERSFORD | KITCHEN PREP BY OFFICE | KITCHEN FAUCET | 2nd sample | <2.5ppb |
| 32-ROY-KF | ROYERSFORD | KITCHEN HAND WASH NEXT TO WALK IN | KITCHEN FAUCET | 2nd sample | <2.5ppb |
| 37-ROY-DO | ROYERSFORD | LG1 | DRINKING OUTLET | 2nd sample | <2.5ppb |
| 38-ROY-EWC | ROYERSFORD | HALLWAY OUTSIDE LAB | ELECTRIC WATER COOLER | 2nd sample | 10.9ppb |
| 23-EVN-KF | EVANS | KITCHEN | KITCHEN FAUCET | 2nd sample | 12.3ppb |
| 24-EVN-KF | EVANS | KITCHEN | KITCHEN FAUCET | 2nd sample | <2.5ppb |
| 21-UPE-KF | UPES | KITCHEN | KITCHEN FAUCET | 2nd sample | 5ppb |
| 23-UPE-KF | UPES | KITCHEN | KITCHEN FAUCET | 2nd sample | 28.7ppb |
| 26-UPE-KF | UPES | KITCHEN | KITCHEN FAUCET | 2nd sample | 16.5ppb |