



Results of Lead in Drinking Water

Client	<u>Spring-Ford Area School District</u>	Site Address	<u>8th Grade</u>	Sample Date	<u>1/5/2019</u>
Project #	<u>182869</u>			Sample Received Date	<u>1/7/2019</u>
Collected By	<u>Criterion Laboratories, Inc.</u>	Analyzed By	<u>Schwab, Andrew</u>	Sample Analysis Date(s)	<u>1/10/2019</u>

Sample Number	Location / Description	Lead (ppb)	Reporting Limit (ppb)
182869-07-023-03-01	1-8GC-CF - Room 110 wall mounted - CLASSROOM FAUCET	< 2.5	2.5
182869-07-023-03-02	2-8GC-CF - Room 112 Hall Side of Room - CLASSROOM FAUCET	< 2.5	2.5
182869-07-023-03-03	3-8GC-EWC - Hall across from Room 110 High - ELECTRIC WATER COOLER	< 2.5	2.5
182869-07-023-03-04	4-8GC-EWC - Hall across from Room 110 Low - ELECTRIC WATER COOLER	< 2.5	2.5
182869-07-023-03-05	5-8GC-EWC - Cafeteria Wall Mounted - ELECTRIC WATER COOLER	< 2.5	2.5
182869-07-023-03-06	6-8GC-KF - Kitchen Double Stainless - KITCHEN FAUCET	56.6144	2.5
182869-07-023-03-07	7-8GC-KF - Kitchen Single wall mounted next to double - KITCHEN FAUCET	< 2.5	2.5
182869-07-023-03-08	8-8GC-KF - Kitchen Triple against hall side wall - KITCHEN FAUCET	10.9	2.5
182869-07-023-03-09	9-8GC-KF - Kitchen Island Sink - KITCHEN FAUCET	< 2.5	2.5
182869-07-023-03-10	10-8GC-KF - Kitchen wall mounted between kitchen and faculty - KITCHEN FAUCET	3.0814	2.5
182869-07-023-03-11	11-8GC-KF - Kitchen Serving Line - KITCHEN FAUCET Left	< 2.5	2.5
182869-07-023-03-12	12-8GC-KF - Kitchen Serving Line - KITCHEN FAUCET right	< 2.5	2.5
182869-07-023-03-13	13-8GC-KF - Kitchen Tray Room - KITCHEN FAUCET	7.4419	2.5
182869-07-023-03-14	14-8GC-KF - Kitchen Tray Room Wall Mounted - KITCHEN FAUCET	30.188	2.5
182869-07-023-03-15	15-8GC-EWC - Main Gym Lobby Wall Mounted - ELECTRIC WATER COOLER	< 2.5	2.5
182869-07-023-03-16	16-8GC-CS - 2nd floor Media Center (records storage) - CLASSROOM FAUCET	5.3899	2.5
182869-07-023-03-17	17-8GC-CF - 2nd Floor Room 209 (Music Office) - CLASSROOM FAUCET	7.4846	2.5
182869-07-023-03-18	18-8GC-EWC - 2nd Floor Hall across Room 207 - ELECTRIC WATER COOLER	< 2.5	2.5
182869-07-023-03-19	19-8GC-EWC - 2nd Floor Hall across Guidance Office High - ELECTRIC WATER COOLER	< 2.5	2.5
182869-07-023-03-20	20-8GC-EWC - 2nd Floor Hall across Guidance Office High - ELECTRIC WATER COOLER	< 2.5	2.5
182869-07-023-03-21	21-8GC-NF - 2nd Floor Nurses Office - FAUCET	< 2.5	2.5
182869-07-023-03-22	22-8GC-NF - 2nd Floor Nurses Office In Exam Room - FAUCET	< 2.5	2.5
182869-07-023-03-23	23-8GC-CF - 2nd Floor Main Office (Mail Room) - CLASSROOM FAUCET	< 2.5	2.5
182869-07-023-03-24	24-8GC-EWC - 2nd Floor Hall across from Auxiliary Gym - ELECTRIC WATER COOLER	< 2.5	2.5
182869-07-023-03-25	25-8GC-EWC - 2nd Floor Girls Locker room - ELECTRIC WATER COOLER	< 2.5	2.5
182869-07-023-03-26	26-8GC-EWC - 3rd Floor Hall across from Room 316 - ELECTRIC WATER COOLER	3.3165	2.5
182869-07-023-03-27	27-8GC-EWC - 3rd Floor Hall across from Room 312 - ELECTRIC WATER COOLER	< 2.5	2.5
182869-07-023-03-28	28-8GC-CS - 3rd Floor Room 32 (FCS) Island Sink #1 - CLASSROOM FAUCET	< 2.5	2.5
182869-07-023-03-29	29-8GC-EWC - 3rd Floor Room 32 (FCS) Island Sink #2 - CLASSROOM FAUCET	< 2.5	2.5
182869-07-023-03-30	30-8GC-EWC - 3rd Floor Room 32 (FCS) Island Sink #3 - CLASSROOM FAUCET	< 2.5	2.5
182869-07-023-03-31	31-8GC-EWC - 3rd Floor Room 32 (FCS) Island Sink #4 - CLASSROOM FAUCET	< 2.5	2.5

Sample Count 31



Results of Lead in Drinking Water

Client	<u>Spring-Ford Area School District</u>	Site Address	<u>8th Grade</u>	Sample Date	<u>1/5/2019</u>
Project #	<u>182869</u>			Sample Received Date	<u>1/7/2019</u>
Collected By	<u>Criterion Laboratories, Inc.</u>	Analyzed By	<u>Schwab, Andrew</u>	Sample Analysis Date(s)	<u>1/10/2019</u>

James A. Wertz, CIH, Technical Director

EPA Action Limit is 15.0 ppb (parts per billion). Criterion Laboratories, Inc. bears no responsibility for sample collection activities of non-Criterion personnel. This report relates only to the samples reported above, and when reproduced, must be in its entirety. QC data associated with this sample set is within acceptable limits. Samples were received in good condition, unless otherwise noted.

Note: If your project number ends with an "R", it is a revised report and replaces the original document in full. Samples are analyzed by Criterion Laboratories, Inc. using EPA Method 200.9: Lead by Graphite Furnace Atomic Absorption (GFAA) and CLI Method 417.

Criterion Laboratories, Inc. (ID 100424) is accredited by the AIHA Laboratory Accreditation Programs (AIHA-LAP), LLC in the IHLAP; EMLAP and ELLAP accreditation programs for Polarized Light Microscopy (PLM), Phase Contrast Microscopy (PCM); Air-Direct Examination; and Airborne Dust, Paint, Settled Dust by Wipe and Soil for Fields of Testing as documented by the Scope of Accreditation Certificate and associated Scope. Additionally, Criterion Laboratories, Inc. is certified by the Center for Disease Control (CDC) Environmental Legionella Isolation Techniques Evaluation (ELITE) Program for the determination of Legionella in water by culture and holds accreditation from the National Voluntary Laboratory Accreditation Program (NVLAP ID 102046-0) for the determination of asbestos in bulk samples by Polarized Light Microscopy (PLM). This test report must not be used to claim product endorsement by NVLAP, NIST, AIHA or any agency of the US Government. Unless specifically listed as above, these test results are not covered under AIHA-LAP, LLC, 100424 accreditation.

THIS IS THE LAST PAGE OF THE REPORT