



## Results of Lead in Drinking Water

Client	<u>Spring-Ford Area School District</u>	Site Address	<u>9th Grade</u>	Sample Date	<u>1/12/2019</u>
Project #	<u>182869</u>			Sample Received Date	<u>1/14/2019</u>
Collected By	<u>Criterion Laboratories, Inc.</u>	Analyzed By	<u>Schwab, Andrew</u>	Sample Analysis Date(s)	<u>1/21/2019</u> <u>1/22/2019</u>

Sample Number	Location / Description	Lead (ppb)	Reporting Limit (ppb)
182869-07-023-06-01	1-9GC-EWC - Girls locker Hallway across fromrm 100 High - ELECTRIC Water Cooler	< 2.5	2.5
182869-07-023-06-02	2-9GC-EWC - Girls locker Hallway across from rm 100 Low - ELECTRIC Water Cooler	< 2.5	2.5
182869-07-023-06-03	3-9GC-EWC - Gym Girls Side High Left - ELECTRIC Water Cooler	< 2.5	2.5
182869-07-023-06-04	4-9GC-EWC - Gym Girls Side Low Right - ELECTRIC Water Cooler	< 2.5	2.5
182869-07-023-06-05	5-9GC-EWC - Gym Boys Side - ELECTRIC Water Cooler	< 2.5	2.5
182869-07-023-06-06	6-9GC-EWC - 100 Hallway between Bathrooms - Boys High - ELECTRIC Water Cooler	< 2.5	2.5
182869-07-023-06-07	7-9GC-EWC - 100 Hallway between Bathrooms - Girls Low - ELECTRIC Water Cooler	< 2.5	2.5
182869-07-023-06-08	8-9GC-EWC - Next to Room 111 High on Left - ELECTRIC Water Cooler	< 2.5	2.5
182869-07-023-06-09	9-9GC-EWC - Next to Room 111 Low on Right - ELECTRIC Water Cooler	< 2.5	2.5
182869-07-023-06-10	10-9GC-EWC - Auditorium Lobby High on Left - ELECTRIC Water Cooler	< 2.5	2.5
182869-07-023-06-11	11-9GC-EWC - Auditorium Lobby Low on Right - ELECTRIC Water Cooler	< 2.5	2.5
182869-07-023-06-12	12-9GC-EWC - Next to Girls Bathroom 200/300/400 Hallways High Left - ELECTRIC Water Cooler	< 2.5	2.5
182869-07-023-06-13	13-9GC-EWC - Next to Girls Bathroom 200/300/400 Hallways Low Right - ELECTRIC Water Cooler	< 2.5	2.5
182869-07-023-06-14	14-9GC-EWC - Across from Rm 407 in 400 hallway High Left - ELECTRIC Water Cooler	< 2.5	2.5
182869-07-023-06-15	15-9GC-EWC - Across from Rm 407 in 400 hallway Low Right - ELECTRIC Water Cooler	< 2.5	2.5
182869-07-023-06-16	16-9GC-EWC - Between Bathrooms 300 Hallway High Left - ELECTRIC Water Cooler	< 2.5	2.5
182869-07-023-06-17	17-9GC-EWC - Between Bathrooms 300 Hallway Low Right - ELECTRIC Water Cooler	< 2.5	2.5
182869-07-023-06-18	18-9GC-EWC - Cafeteria High Left - ELECTRIC Water Cooler	< 2.5	2.5
182869-07-023-06-19	19-9GC-EWC - Cafeteria Low Right - ELECTRIC Water Cooler	< 2.5	2.5
182869-07-023-06-20	20-9GC-KF - Kitchen Ala Carte Line - KITCHEN FAUCET	< 2.5	2.5
182869-07-023-06-21	21-9GC-KF - Kitchen Sink Faucet #1 - KITCHEN FAUCET	< 2.5	2.5
182869-07-023-06-22	22-9GC-KF - Kitchen Sink Faucet #2 - KITCHEN FAUCET	< 2.5	2.5
182869-07-023-06-23	23-9GC-KF - Kitchen Sink Faucet #3 - KITCHEN FAUCET	< 2.5	2.5
182869-07-023-06-24	24-9GC-KF - Kitchen Cooking Area Sink Faucet #4 - KITCHEN FAUCET	8.142	2.5
182869-07-023-06-25	25-9GC-KF - Kitchen Dish Room - KITCHEN FAUCET	8.3361	2.5
182869-07-023-06-26	26-9GC-KF - Kitchen Service Line #1 - KITCHEN FAUCET	< 2.5	2.5
182869-07-023-06-27	27-9GC-KF - Kitchen Service Line #2 - KITCHEN FAUCET	< 2.5	2.5
182869-07-023-06-28	28-9GC-TL - Faculty Dining Room Sink - Teacher Lounge Faucet	< 2.5	2.5
182869-07-023-06-29	29-9GC-F - Media Center Back Room - FAUCET	6.2788	2.5
182869-07-023-06-30	30-9GC-F - Main Office Mail Room - FAUCET	4.1	2.5
182869-07-023-06-31	31-9GC-NF - Nurses Office Exam Room - NURSE FAUCET	< 2.5	2.5
182869-07-023-06-32	32-9GC-NF - Nurse Office Room with Beds - NURSE FAUCET	< 2.5	2.5
182869-07-023-06-33	33-9GC-CF - Music Room 118 Ride Side of Door - CLASSROOM FAUCET	16.2159	2.5



## Results of Lead in Drinking Water

Client	<u>Spring-Ford Area School District</u>	Site Address	<u>9th Grade</u>	Sample Date	<u>1/12/2019</u>
Project #	<u>182869</u>			Sample Received Date	<u>1/14/2019</u>
Collected By	<u>Criterion Laboratories, Inc.</u>	Analyzed By	<u>Schwab, Andrew</u>	Sample Analysis Date(s)	<u>1/21/2019</u> <u>1/22/2019</u>

Sample Number	Location / Description	Lead (ppb)	Reporting Limit (ppb)
182869-07-023-06-34	34-9GC-F - Stage - FAUCET	20.99	2.5
182869-07-023-06-35	35-9GC-CF - Room 204 - CLASSROOM FAUCET	< 2.5	2.5
182869-07-023-06-36	36-9GC-CF - Room 205 Station 1 - CLASSROOM FAUCET	< 2.5	2.5
182869-07-023-06-37	37-9GC-CF - Room 205 Station 2 - CLASSROOM FAUCET	< 2.5	2.5
182869-07-023-06-38	38-9GC-CF - Room 205 Station 3 - CLASSROOM FAUCET	< 2.5	2.5
182869-07-023-06-39	39-9GC-CF - Room 205 Station 3 - CLASSROOM FAUCET	< 2.5	2.5
182869-07-023-06-40	40-9GC-CF - Room 205 Right of Main Door - CLASSROOM FAUCET	64.7476	2.5
182869-07-023-06-41	41-9GC-CF - Teachers Workroom at 200/300/400 Hallway - TEACHER LOUNGE FAUCET	2.7384	2.5
182869-07-023-06-42	58-9GC-CF - Room 314 - CLASSROOM FAUCET	< 2.5	2.5
182869-07-023-06-43	59-9GC-EWC - Boys locker room - ELECTRIC Water Cooler	< 2.5	2.5
182869-07-023-06-44	60-9GC-EWC - Faculty Dining Room - ELECTRIC Water Cooler	< 2.5	2.5
182869-07-023-06-45	61-9GC-EWC - Girls locker room - ELECTRIC Water Cooler	< 2.5	2.5
182869-07-023-06-46	62-9GC-EWC - Inside of room 314 - ELECTRIC Water Cooler	< 2.5	2.5

Sample Count 46

James A. Weltz, CIH, Technical Director

EPA Action Limit is 15.0 ppb (parts per billion). Criterion Laboratories, Inc. bears no responsibility for sample collection activities of non-Criterion personnel. This report relates only to the samples reported above, and when reproduced, must be in its entirety. QC data associated with this sample set is within acceptable limits. Samples were received in good condition, unless otherwise noted.

Note: If your project number ends with an "R", it is a revised report and replaces the original document in full. Samples are analyzed by Criterion Laboratories, Inc. using EPA Method 200.9: Lead by Graphite Furnace Atomic Absorption (GFAA) and CLI Method 417.

Criterion Laboratories, Inc. (ID 100424) is accredited by the AIHA Laboratory Accreditation Programs (AIHA-LAP), LLC in the IHLAP; EMLAP and ELLAP accreditation programs for Polarized Light Microscopy (PLM), Phase Contrast Microscopy (PCM); Air-Direct Examination; and Airborne Dust, Paint, Settled Dust by Wipe and Soil for Fields of Testing as documented by the Scope of Accreditation Certificate and associated Scope. Additionally, Criterion Laboratories, Inc. is certified by the Center for Disease Control (CDC) Environmental Legionella Isolation Techniques Evaluation (ELITE) Program for the determination of Legionella in water by culture and holds accreditation from the National Voluntary Laboratory Accreditation Program (NVLAP ID 102046-0) for the determination of asbestos in bulk samples by Polarized Light Microscopy (PLM). This test report must not be used to claim product endorsement by NVLAP, NIST, AIHA or any agency of the US Government. Unless specifically listed as above, these test results are not covered under AIHA-LAP, LLC, 100424 accreditation.

**THIS IS THE LAST PAGE OF THE REPORT**