



## Results of Lead in Drinking Water

Client	<u>Spring-Ford Area School District</u>	Site Address	<u>Brooke Elementary</u>	Sample Date	<u>1/12/2019</u>
Project #	<u>182869</u>			Sample Received Date	<u>1/14/2019</u>
Collected By	<u>Criterion Laboratories, Inc.</u>	Analyzed By	<u>Schwab, Andrew</u>	Sample Analysis Date(s)	<u>1/17/2019</u> <u>1/18/2019</u>

Sample Number	Location / Description	Lead (ppb)	Reporting Limit (ppb)
182869-07-023-07-01	1-BRK-CF - ROOM 6 - CLASSROOM FAUCET LEFT	< 2.5	2.5
182869-07-023-07-02	2-BRK-CF - ROOM 6 - CLASSROOM FAUCET RIGHT	< 2.5	2.5
182869-07-023-07-03	3-BRK-EWC - ROOM 6 - ELECTRIC WATER COOLER	< 2.5	2.5
182869-07-023-07-04	4-BRK-CF - ROOM 5 - CLASSROOM FAUCET LEFT	< 2.5	2.5
182869-07-023-07-05	5-BRK-CF - ROOM 5 - CLASSROOM FAUCET RIGHT	< 2.5	2.5
182869-07-023-07-06	6-BRK-EWC - ROOM 5 - ELECTRIC WATER COOLER	< 2.5	2.5
182869-07-023-07-07	7-BRK-DO - ROOM 4 - DRINKING OUTLET	< 2.5	2.5
182869-07-023-07-08	8-BRK-DO - ROOM 3 - DRINKING OUTLET	< 2.5	2.5
182869-07-023-07-09	9-BRK-DO - ROOM 2 - DRINKING OUTLET	< 2.5	2.5
182869-07-023-07-10	10-BRK-DO - ROOM 1 - DRINKING OUTLET	< 2.5	2.5
182869-07-023-07-11	11-BRK-DO - ROOM 8 - DRINKING OUTLET	< 2.5	2.5
182869-07-023-07-12	12-BRK-DO - ROOM 9 - DRINKING OUTLET	< 2.5	2.5
182869-07-023-07-13	13-BRK-DO - ROOM 10 - DRINKING OUTLET	< 2.5	2.5
182869-07-023-07-14	14-BRK-DO - ROOM 11 - DRINKING OUTLET	< 2.5	2.5
182869-07-023-07-15	15-BRK-DO - ROOM 12 - DRINKING OUTLET	< 2.5	2.5
182869-07-023-07-16	16-BRK-DO - ROOM 13 - DRINKING OUTLET	< 2.5	2.5
182869-07-023-07-17	17-BRK-DO - ROOM 15 - DRINKING OUTLET	< 2.5	2.5
182869-07-023-07-18	18-BRK-DO - ROOM 16 - DRINKING OUTLET	< 2.5	2.5
182869-07-023-07-19	19-BRK-DO - ROOM 17 - DRINKING OUTLET	< 2.5	2.5
182869-07-023-07-20	20-BRK-DO - ROOM 18 - DRINKING OUTLET	< 2.5	2.5
182869-07-023-07-21	21-BRK-DO - ROOM 19 - DRINKING OUTLET	< 2.5	2.5
182869-07-023-07-22	22-BRK-DO - ROOM 20 - DRINKING OUTLET	< 2.5	2.5
182869-07-023-07-23	23-BRK-DO - ROOM 21 - DRINKING OUTLET	< 2.5	2.5
182869-07-023-07-24	24-BRK-DO - ROOM 23 - DRINKING OUTLET	< 2.5	2.5
182869-07-023-07-25	25-BRK-DO - ROOM 24 - DRINKING OUTLET	< 2.5	2.5
182869-07-023-07-26	26-BRK-DO - ROOM 25 - DRINKING OUTLET	< 2.5	2.5
182869-07-023-07-27	27-BRK-DO - ROOM 26 - DRINKING OUTLET	< 2.5	2.5
182869-07-023-07-28	28-BRK-DO - ROOM 27 - DRINKING OUTLET	< 2.5	2.5
182869-07-023-07-29	29-BRK-DO - ROOM 28 - DRINKING OUTLET	< 2.5	2.5
182869-07-023-07-30	30-BRK-DO - ROOM 29 - DRINKING OUTLET	< 2.5	2.5
182869-07-023-07-31	31-BRK-DO - ROOM 30 - DRINKING OUTLET	--- Not Received ---	
182869-07-023-07-32	32-BRK-CF - ROOM 32 - CLASSROOM FAUCET	< 2.5	2.5
182869-07-023-07-33	33-BRK-EWC - OUSIDE OF WORK ROOM - ELECTRIC WATER COOLER	< 2.5	2.5



## Results of Lead in Drinking Water

Client	<u>Spring-Ford Area School District</u>	Site Address	<u>Brooke Elementary</u>	Sample Date	<u>1/12/2019</u>
Project #	<u>182869</u>			Sample Received Date	<u>1/14/2019</u>
Collected By	<u>Criterion Laboratories, Inc.</u>	Analyzed By	<u>Schwab, Andrew</u>	Sample Analysis Date(s)	<u>1/17/2019</u> <u>1/18/2019</u>

Sample Number	Location / Description	Lead (ppb)	Reporting Limit (ppb)
182869-07-023-07-34	34-BRK-F - WORK ROOM - FAUCET	< 2.5	2.5
182869-07-023-07-35	35-BRK-F - LIBRARY OFFICE - FAUCET	< 2.5	2.5
182869-07-023-07-36	36-BRK-F - MAIN OFFICE - FAUCET	< 2.5	2.5
182869-07-023-07-37	37-BRK-EWC - MAIN OFFICE - ELECTRIC WATER COOLER	< 2.5	2.5
182869-07-023-07-38	38-BRK-NF - NURSE EXAM ROOM - NURSE FAUCET	< 2.5	2.5
182869-07-023-07-39	39-BRK-NF - NURSE LARGE ROOM - NURSE FAUCET	5.8791	2.5
182869-07-023-07-40	40-BRK-EWC - CAFETERIA - ELECTRIC WATER COOLER	< 2.5	2.5
182869-07-023-07-41	41-BRK-EWC - HALL OUTSIDE CAFETERIA AT BATHROOMS - ELECTRIC WATER COOLER	< 2.5	2.5
182869-07-023-07-42	42-BRK-TL - FACULTY DINING - TEACHER LOUNGE FAUCET	< 2.5	2.5
182869-07-023-07-43	43-BRK-CF - Music room - CLASSROOM FAUCET	< 2.5	2.5
182869-07-023-07-44	44-BRK-KF - KITCHEN PREP FAUCET - KITCHEN	< 2.5	2.5
182869-07-023-07-45	45-BRK-KF - KITCHEN WASH FAUCET - KITCHEN	< 2.5	2.5
182869-07-023-07-46	46-BRK-KF - KITCHEN RINSE FAUCET - KITCHEN	< 2.5	2.5
182869-07-023-07-47	47-BRK-KF - KITCHEN FAUCET ON BACK WALL - KITCHEN	6.4295	2.5
182869-07-023-07-48	48-BRK-KF - KITCHEN FAUCET NEXT TO ICE MACHINE - KITCHEN	< 2.5	2.5
182869-07-023-07-49	49-BRK-KF - KITCHEN ICE MACHINE - ICE MACHINE	< 2.5	2.5
182869-07-023-07-50	50-BRK-EWC - HALLWAY OUTSIDE ROOM 17 - ELECTRIC WATER COOLER	< 2.5	2.5
182869-07-023-07-51	51-BRK-EWC - HALLWAY OUTSIDE STORE ROOM C - ELECTRIC WATER COOLER	< 2.5	2.5
182869-07-023-07-52	52-BRK-DO - ROOM 14 - ELECTRIC WATER COOLER	< 2.5	2.5
182869-07-023-07-53	53-BRK-EWC - BY ROOM 7 - ELECTRIC WATER COOLER	< 2.5	2.5
182869-07-023-07-54	54-BRK-EWC - BY ROOM 13 - ELECTRIC WATER COOLER	< 2.5	2.5
182869-07-023-07-55	55-BRK-EWC - BY ROOM 22 - ELECTRIC WATER COOLER	< 2.5	2.5
182869-07-023-07-56	56-BRK-EWC - BY ROOM 28 - ELECTRIC WATER COOLER	< 2.5	2.5

Sample Count 55

James A. Wetz, CIH, Technical Director

EPA Action Limit is 15.0 ppb (parts per billion). Criterion Laboratories, Inc. bears no responsibility for sample collection activities of non-Criterion personnel. This report relates only to the samples reported above, and when reproduced, must be in its entirety. QC data associated with this sample set is within acceptable limits. Samples were received in good condition, unless otherwise noted.

Note: If your project number ends with an "R", it is a revised report and replaces the original document in full. Samples are analyzed by Criterion Laboratories, Inc. using EPA Method 200.9: Lead by Graphite Furnace Atomic Absorption (GFAA) and CLI Method 417.