



## Results of Lead in Drinking Water

Client	<u>Spring-Ford Area School District</u>	Site Address	<u>District Office - 857 South Lewis Road, Royersford, PA 19468-2732</u>	Sample Date	<u>1/19/2019</u>
Project #	<u>182869</u>			Sample Received Date	<u>1/23/2019</u>
Collected By	<u>Criterion Laboratories, Inc.</u>	Analyzed By	<u>Schwab, Andrew</u>	Sample Analysis Date(s)	<u>2/5/2019</u>

Sample Number	Location / Description	Lead (ppb)	Reporting Limit (ppb)
182869-07-023-12-01	1-DO-F - BREAK ROOM - DRINKING OUTLET	< 2.5	2.5
182869-07-023-12-02	2-DO-EWC - MAIN ENTRANCE HALLWAY - ELECTRIC WATER COOLER	< 2.5	2.5

Sample Count   2  

James A. Weltz, CIH, Technical Director

EPA Action Limit is 15.0 ppb (parts per billion). Criterion Laboratories, Inc. bears no responsibility for sample collection activities of non-Criterion personnel. This report relates only to the samples reported above, and when reproduced, must be in its entirety. QC data associated with this sample set is within acceptable limits. Samples were received in good condition, unless otherwise noted.

Note: If your project number ends with an "R", it is a revised report and replaces the original document in full. Samples are analyzed by Criterion Laboratories, Inc. using EPA Method 200.9: Lead by Graphite Furnace Atomic Absorption (GFAA) and CLI Method 417.

Criterion Laboratories, Inc. (ID 100424) is accredited by the AIHA Laboratory Accreditation Programs (AIHA-LAP), LLC in the IHLAP; EMLAP and ELLAP accreditation programs for Polarized Light Microscopy (PLM), Phase Contrast Microscopy (PCM); Air-Direct Examination; and Airborne Dust, Paint, Settled Dust by Wipe and Soil for Fields of Testing as documented by the Scope of Accreditation Certificate and associated Scope. Additionally, Criterion Laboratories, Inc. is certified by the Center for Disease Control (CDC) Environmental Legionella Isolation Techniques Evaluation (ELITE) Program for the determination of Legionella in water by culture and holds accreditation from the National Voluntary Laboratory Accreditation Program (NVLAP ID 102046-0) for the determination of asbestos in bulk samples by Polarized Light Microscopy (PLM). This test report must not be used to claim product endorsement by NVLAP, NIST, AIHA or any agency of the US Government. Unless specifically listed as above, these test results are not covered under AIHA-LAP, LLC, 100424 accreditation.

**THIS IS THE LAST PAGE OF THE REPORT**