



Results of Lead in Drinking Water

Client	<u>Spring-Ford Area School District</u>	Site Address	<u>Evans Elementary School, 125 Sunset Rd,</u>	Sample Date	<u>1/19/2019</u>
Project #	<u>182869</u>		<u>Limerick, PA 19468</u>	Sample Received Date	<u>1/29/2019</u>
Collected By	<u>Criterion Laboratories, Inc.</u>	Analyzed By	<u>Schwab, Andrew</u>	Sample Analysis Date(s)	<u>1/31/2019</u> <u>2/1/2019</u> <u>2/4/2019</u>

Sample Number	Location / Description	Lead (ppb)	Reporting Limit (ppb)
182869-07-023-09-01	1-EVN-DO - MEDIA CENTER WORK ROOM - DRINKING OUTLET	< 2.5	2.5
182869-07-023-09-02	2-EVN-DO - ROOM 105 - DRINKING OUTLET	< 2.5	2.5
182869-07-023-09-03	3-EVN-DO - ROOM 107 - DRINKING OUTLET	< 2.5	2.5
182869-07-023-09-04	4-EVN-DO - ROOM 109 - DRINKING OUTLET	< 2.5	2.5
182869-07-023-09-05	5-EVN-DO - ROOM 111 - DRINKING OUTLET	< 2.5	2.5
182869-07-023-09-06	6-EVN-DO - ROOM 113 - DRINKING OUTLET	< 2.5	2.5
182869-07-023-09-07	7-EVN-DO - ROOM 115 - DRINKING OUTLET	< 2.5	2.5
182869-07-023-09-08	8-EVN-DO - ROOM 119 - DRINKING OUTLET	< 2.5	2.5
182869-07-023-09-09	9-EVN-DO - ROOM 121 - DRINKING OUTLET	< 2.5	2.5
182869-07-023-09-10	10-EVN-DO - ROOM 122 - DRINKING OUTLET	< 2.5	2.5
182869-07-023-09-11	11-EVN-DO - ROOM 118 - CLASSROOM FAUCET	11.12	2.5
182869-07-023-09-12	12-EVN-NF - ROOM NURSE'S SUITE - NURSE FAUCET	< 2.5	2.5
182869-07-023-09-13	13-EVN-NF - ROOM NURSE'S SUITE - NURSE FAUCET	< 2.5	2.5
182869-07-023-09-14	14-EVN-NF - ROOM NURSE'S SUITE - NURSE FAUCET	< 2.5	2.5
182869-07-023-09-15	15-EVN-EWC - CORRIDOR OUTSIDE OF NURSE'S SUITE - ELECTRIC WATER COOLER HIGH	< 2.5	2.5
182869-07-023-09-16	16-EVN-EWC - CORRIDOR OUTSIDE OF NURSE'S SUITE - ELECTRIC WATER COOLER LOW	< 2.5	2.5
182869-07-023-09-17	17-EVN-EWC - OUTSIDE OF GIRLS BATHROOM 2ND FLOOR - ELECTRIC WATER COOLER HIGH	< 2.5	2.5
182869-07-023-09-18	18-EVN-EWC - OUTSIDE OF GIRLS BATHROOM 2ND FLOOR - ELECTRIC WATER COOLER LOW	< 2.5	2.5
182869-07-023-09-19	19-EVN-TL - FACULTY DINING - TEACHER LOUNGE FAUCET	< 2.5	2.5
182869-07-023-09-20	20-EVN-KF - KITCHEN - KITCHEN FAUCET	6.7	2.5
182869-07-023-09-21	21-EVN-KF - KITCHEN - KITCHEN FAUCET	< 2.5	2.5
182869-07-023-09-22	22-EVN-KF - KITCHEN - KITCHEN FAUCET	< 2.5	2.5
182869-07-023-09-23	23-EVN-KF - KITCHEN - KITCHEN FAUCET	256.0	2.5
182869-07-023-09-24	24-EVN-KF - KITCHEN - KITCHEN FAUCET	29.6656	2.5
182869-07-023-09-25	25-EVN-KF - KITCHEN - KITCHEN FAUCET	5.3	2.5
182869-07-023-09-26	26-EVN-KF - KITCHEN - KITCHEN FAUCET	11.8572	2.5
182869-07-023-09-27	27-EVN-KF - KITCHEN - KITCHEN FAUCET	6.0382	2.5
182869-07-023-09-28	29-EVN-DO - ROOM 110 - DRINKING OUTLET	< 2.5	2.5
182869-07-023-09-29	30-EVN-DO - ROOM 108 - DRINKING OUTLET	< 2.5	2.5
182869-07-023-09-30	31-EVN-DO - ROOM 106 - DRINKING OUTLET	< 2.5	2.5
182869-07-023-09-31	32-EVN-DO - ROOM 143 - DRINKING OUTLET	< 2.5	2.5
182869-07-023-09-32	33-EVN-DO - ROOM 145 - DRINKING OUTLET	< 2.5	2.5



Results of Lead in Drinking Water

Client	<u>Spring-Ford Area School District</u>	Site Address	<u>Evans Elementary School, 125 Sunset Rd, Limerick, PA 19468</u>	Sample Date	<u>1/19/2019</u>
Project #	<u>182869</u>			Sample Received Date	<u>1/29/2019</u>
Collected By	<u>Criterion Laboratories, Inc.</u>	Analyzed By	<u>Schwab, Andrew</u>	Sample Analysis Date(s)	<u>1/31/2019 2/1/2019 2/4/2019</u>

Sample Number	Location / Description	Lead (ppb)	Reporting Limit (ppb)
182869-07-023-09-33	34-EVN-DO - ROOM 149 - DRINKING OUTLET	< 2.5	2.5
182869-07-023-09-34	35-EVN-DO - ROOM 148 - DRINKING OUTLET	< 2.5	2.5
182869-07-023-09-35	36-EVN-DO - ROOM 144 - DRINKING OUTLET	< 2.5	2.5
182869-07-023-09-36	37-EVN-DO - ROOM 142 - DRINKING OUTLET	< 2.5	2.5
182869-07-023-09-37	38-EVN-DO - ROOM 100 - DRINKING OUTLET	< 2.5	2.5
182869-07-023-09-38	39-EVN-DO - ROOM 201 - DRINKING OUTLET	< 2.5	2.5
182869-07-023-09-39	40-EVN-DO - ROOM 203 - DRINKING OUTLET	8.7	2.5
182869-07-023-09-40	41-EVN-DO - ROOM 205 - DRINKING OUTLET	< 2.5	2.5
182869-07-023-09-41	42-EVN-DO - ROOM 207 - DRINKING OUTLET	< 2.5	2.5
182869-07-023-09-42	43-EVN-DO - ROOM 209 - DRINKING OUTLET	< 2.5	2.5
182869-07-023-09-43	44-EVN-DO - ROOM 211 - DRINKING OUTLET	< 2.5	2.5
182869-07-023-09-44	45-EVN-DO - ROOM 213 - DRINKING OUTLET	< 2.5	2.5
182869-07-023-09-45	46-EVN-DO - ROOM 215 - DRINKING OUTLET	< 2.5	2.5
182869-07-023-09-46	47-EVN-DO - ROOM 219 - DRINKING OUTLET	< 2.5	2.5
182869-07-023-09-47	48-EVN-DO - ROOM 221 - DRINKING OUTLET	< 2.5	2.5
182869-07-023-09-48	49-EVN-EWC - OUTSIDE OF BOYS BATHROOM 1ST FLOOR - ELECTRIC WATER COOLER HIGH	< 2.5	2.5
182869-07-023-09-49	50-EVN-EWC - OUTSIDE OF BOYS BATHROOM 1ST FLOOR - ELECTRIC WATER COOLER LOW	< 2.5	2.5
182869-07-023-09-50	51-EVN-EWC - OUTSIDE OF GIRLS BATHROOM 1ST FLOOR - ELECTRIC WATER COOLER HIGH	< 2.5	2.5
182869-07-023-09-51	52-EVN-EWC - OUTSIDE OF GIRLS BATHROOM 1ST FLOOR - ELECTRIC WATER COOLER LOW	< 2.5	2.5
182869-07-023-09-52	53-EVN-CF - ROOM 240 - CLASSROOM FAUCET	< 2.5	2.5
182869-07-023-09-53	54-EVN-DO - ROOM 222 - DRINKING OUTLET	< 2.5	2.5
182869-07-023-09-54	55-EVN-DO - ROOM 218 - DRINKING OUTLET	< 2.5	2.5
182869-07-023-09-55	56-EVN-DO - ROOM 210 - DRINKING OUTLET	< 2.5	2.5
182869-07-023-09-56	57-EVN-DO - ROOM 208 - DRINKING OUTLET	< 2.5	2.5
182869-07-023-09-57	58-EVN-DO - ROOM 206 - DRINKING OUTLET	< 2.5	2.5
182869-07-023-09-58	59-EVN-EWC - OUTSIDE BOYS BATHROOM 2ND FLOOR - ELECTRIC WATER COOLER HIGH	< 2.5	2.5
182869-07-023-09-59	60-EVN-EWC - OUTSIDE BOYS BATHROOM 2ND FLOOR - ELECTRIC WATER COOLER LOW	< 2.5	2.5
182869-07-023-09-60	61-EVN-DO - ROOM 243 - DRINKING OUTLET	< 2.5	2.5
182869-07-023-09-61	62-EVN-DO - ROOM 245 - DRINKING OUTLET	< 2.5	2.5
182869-07-023-09-62	63-EVN-DO - ROOM 249 - DRINKING OUTLET	< 2.5	2.5
182869-07-023-09-63	64-EVN-DO - ROOM 248 - DRINKING OUTLET	< 2.5	2.5
182869-07-023-09-64	65-EVN-DO - ROOM 244 - DRINKING OUTLET	< 2.5	2.5



Results of Lead in Drinking Water

Client	<u>Spring-Ford Area School District</u>	Site Address	<u>Evans Elementary School, 125 Sunset Rd, Limerick, PA 19468</u>	Sample Date	<u>1/19/2019</u>
Project #	<u>182869</u>			Sample Received Date	<u>1/29/2019</u>
Collected By	<u>Criterion Laboratories, Inc.</u>	Analyzed By	<u>Schwab, Andrew</u>	Sample Analysis Date(s)	<u>1/31/2019 2/1/2019 2/4/2019</u>

Sample Number	Location / Description	Lead (ppb)	Reporting Limit (ppb)
182869-07-023-09-65	66-EVN-DO - ROOM 240 - DRINKING OUTLET	< 2.5	2.5
182869-07-023-09-66	67-EVN-CF - MAIN OFFICE WORK ROOM - FAUCET	< 2.5	2.5
182869-07-023-09-67	68-EVN-EWC - CAFETERIA - ELECTRIC WATER COOLER	< 2.5	2.5

Sample Count 67

James A. Wertz, CIH, Technical Director

EPA Action Limit is 15.0 ppb (parts per billion). Criterion Laboratories, Inc. bears no responsibility for sample collection activities of non-Criterion personnel. This report relates only to the samples reported above, and when reproduced, must be in its entirety. QC data associated with this sample set is within acceptable limits. Samples were received in good condition, unless otherwise noted.

Note: If your project number ends with an "R", it is a revised report and replaces the original document in full. Samples are analyzed by Criterion Laboratories, Inc. using EPA Method 200.9: Lead by Graphite Furnace Atomic Absorption (GFAA) and CLI Method 417.

Criterion Laboratories, Inc. (ID 100424) is accredited by the AIHA Laboratory Accreditation Programs (AIHA-LAP), LLC in the IHLAP; EMLAP and ELLAP accreditation programs for Polarized Light Microscopy (PLM), Phase Contrast Microscopy (PCM); Air-Direct Examination; and Airborne Dust, Paint, Settled Dust by Wipe and Soil for Fields of Testing as documented by the Scope of Accreditation Certificate and associated Scope. Additionally, Criterion Laboratories, Inc. is certified by the Center for Disease Control (CDC) Environmental Legionella Isolation Techniques Evaluation (ELITE) Program for the determination of Legionella in water by culture and holds accreditation from the National Voluntary Laboratory Accreditation Program (NVLAP ID 102046-0) for the determination of asbestos in bulk samples by Polarized Light Microscopy (PLM). This test report must not be used to claim product endorsement by NVLAP, NIST, AIHA or any agency of the US Government. Unless specifically listed as above, these test results are not covered under AIHA-LAP, LLC, 100424 accreditation.

THIS IS THE LAST PAGE OF THE REPORT