



Results of Lead in Drinking Water

Client	<u>Spring-Ford Area School District</u>	Site Address	<u>Upper Providence Elementary - 833 S Lewis Rd, Royersford, PA 19468</u>	Sample Date	<u>1/19/2019</u>
Project #	<u>182869</u>			Sample Received Date	<u>1/23/2019</u>
Collected By	<u>Criterion Laboratories, Inc.</u>	Analyzed By	<u>Schwab, Andrew</u>	Sample Analysis Date(s)	<u>2/4/2019</u> <u>2/5/2019</u>

Sample Number	Location / Description	Lead (ppb)	Reporting Limit (ppb)
182869-07-023-10-01	1-UPE-KF - STAFF DINING - KITCHEN FAUCET	< 2.5	2.5
182869-07-023-10-02	2-UPE-DO - ROOM 242 - DRINKING OUTLET	< 2.5	2.5
182869-07-023-10-03	3-UPE-DO - ROOM 243 - DRINKING OUTLET	< 2.5	2.5
182869-07-023-10-04	4-UPE-DO - ROOM 244 - DRINKING OUTLET	< 2.5	2.5
182869-07-023-10-05	5-UPE-DO - ROOM 245 - DRINKING OUTLET	< 2.5	2.5
182869-07-023-10-06	6-UPE-DO - ROOM 246 - DRINKING OUTLET	< 2.5	2.5
182869-07-023-10-07	7-UPE-DO - ROOM 226 - DRINKING OUTLET	< 2.5	2.5
182869-07-023-10-08	8-UPE-DO - ROOM 227 - DRINKING OUTLET	< 2.5	2.5
182869-07-023-10-09	9-UPE-DO - ROOM 247 - DRINKING OUTLET	2.876	2.5
182869-07-023-10-10	10-UPE-DO - ROOM 248 - DRINKING OUTLET	3.8211	2.5
182869-07-023-10-11	11-UPE-DO - ROOM 229 - DRINKING OUTLET	< 2.5	2.5
182869-07-023-10-12	12-UPE-DO - ROOM 230 - DRINKING OUTLET	< 2.5	2.5
182869-07-023-10-13	13-UPE-DO - ROOM 231 - DRINKING OUTLET	< 2.5	2.5
182869-07-023-10-14	14-UPE-DO - ROOM 232 - DRINKING OUTLET	< 2.5	2.5
182869-07-023-10-15	15-UPE-DO - ROOM 233 - DRINKING OUTLET	< 2.5	2.5
182869-07-023-10-16	16-UPE-DO - ROOM 234 - DRINKING OUTLET	< 2.5	2.5
182869-07-023-10-17	17-UPE-EWC - MAIN FLOOR BY GIRLS BATHROOM - ELECTRIC WATER COOLER HIGH	< 2.5	2.5
182869-07-023-10-18	18-UPE-EWC - MAIN FLOOR BY GIRLS BATHROOM - ELECTRIC WATER COOLER LOW	< 2.5	2.5
182869-07-023-10-19	19-UPE-EWC - MAIN FLOOR BY BOYS BATHROOM - ELECTRIC WATER COOLER HIGH	< 2.5	2.5
182869-07-023-10-20	20-UPE-EWC - MAIN FLOOR BY BOYS BATHROOM - ELECTRIC WATER COOLER LOW	< 2.5	2.5
182869-07-023-10-21	21-UPE-KF - KITCHEN - KITCHEN FAUCET	50.0	2.5
182869-07-023-10-22	22-UPE-KF - KITCHEN - KITCHEN FAUCET	< 2.5	2.5
182869-07-023-10-23	23-UPE-KF - KITCHEN - KITCHEN FAUCET	87.535	2.5
182869-07-023-10-24	24-UPE-KF - KITCHEN - KITCHEN FAUCET	< 2.5	2.5
182869-07-023-10-25	25-UPE-KF - KITCHEN - KITCHEN FAUCET	3.4272	2.5
182869-07-023-10-26	26-UPE-KF - KITCHEN - KITCHEN FAUCET	96.2766	2.5
182869-07-023-10-27	27-UPE-KF - KITCHEN - KITCHEN FAUCET	2.6398	2.5
182869-07-023-10-28	28-UPE-KF - KITCHEN - KITCHEN FAUCET	3.23	2.5
182869-07-023-10-29	31-UPE-DO - ROOM 249 - DRINKING OUTLET	< 2.5	2.5
182869-07-023-10-30	32-UPE-DO - ROOM 250 - DRINKING OUTLET	< 2.5	2.5
182869-07-023-10-31	33-UPE-DO - ROOM 236 - DRINKING OUTLET	< 2.5	2.5
182869-07-023-10-32	34-UPE-DO - ROOM 237 - DRINKING OUTLET	< 2.5	2.5
182869-07-023-10-33	35-UPE-DO - ROOM 238 - DRINKING OUTLET	< 2.5	2.5



Results of Lead in Drinking Water

Client	<u>Spring-Ford Area School District</u>	Site Address	<u>Upper Providence Elementary - 833 S Lewis Rd, Royersford, PA 19468</u>	Sample Date	<u>1/19/2019</u>
Project #	<u>182869</u>			Sample Received Date	<u>1/23/2019</u>
Collected By	<u>Criterion Laboratories, Inc.</u>	Analyzed By	<u>Schwab, Andrew</u>	Sample Analysis Date(s)	<u>2/4/2019</u> <u>2/5/2019</u>

Sample Number	Location / Description	Lead (ppb)	Reporting Limit (ppb)
182869-07-023-10-34	36-UPE-DO - ROOM 205 - DRINKING OUTLET	< 2.5	2.5
182869-07-023-10-35	37-UPE-DO - ROOM 115 - DRINKING OUTLET	5.6521	2.5
182869-07-023-10-36	38-UPE-DO - ROOM 115 - DRINKING OUTLET	2.5217	2.5
182869-07-023-10-37	39-UPE-DO - ROOM 116 - ELECTRIC WATER COOLER HIGH	< 2.5	2.5
182869-07-023-10-38	40-UPE-DO - ROOM 117 - ELECTRIC WATER COOLER LOW	< 2.5	2.5
182869-07-023-10-39	41-UPE-DO - ROOM 118 - ELECTRIC WATER COOLER	< 2.5	2.5
182869-07-023-10-40	42-UPE-DO - ROOM 119 - DRINKING OUTLET	< 2.5	2.5
182869-07-023-10-41	43-UPE-DO - ROOM 120 - DRINKING OUTLET	< 2.5	2.5
182869-07-023-10-42	44-UPE-DO - ROOM 100 - DRINKING OUTLET	< 2.5	2.5
182869-07-023-10-43	45-UPE-DO - ROOM 102 - DRINKING OUTLET	< 2.5	2.5
182869-07-023-10-44	46-UPE-DO - ROOM 121 - DRINKING OUTLET	< 2.5	2.5
182869-07-023-10-45	47-UPE-NF - NURSE OFFICE - NURSE FAUCET	< 2.5	2.5
182869-07-023-10-46	48-UPE-NF - NURSE OFFICE - NURSE FAUCET	< 2.5	2.5
182869-07-023-10-47	49-UPE-NF - NURSE OFFICE - NURSE FAUCET	< 2.5	2.5
182869-07-023-10-48	50-UPE-EWC - GIRLS BATHROOM GROUND FLOOR - ELECTRIC WATER COOLER HIGH	< 2.5	2.5
182869-07-023-10-49	51-UPE-EWC - GIRLS BATHROOM GROUND FLOOR - ELECTRIC WATER COOLER LOW	< 2.5	2.5
182869-07-023-10-50	52-UPE-EWC - BOYS BATHROOM GROUND FLOOR - ELECTRIC WATER COOLER HIGH	< 2.5	2.5
182869-07-023-10-51	53-UPE-EWC - BOYS BATHROOM GROUND FLOOR - ELECTRIC WATER COOLER LOW	< 2.5	2.5
182869-07-023-10-52	54-UPE-DO - ROOM 105 - DRINKING OUTLET	< 2.5	2.5
182869-07-023-10-53	55-UPE-DO - ROOM 104 - DRINKING OUTLET	< 2.5	2.5
182869-07-023-10-54	56-UPE-DO - ROOM 122 - DRINKING OUTLET	7.7681	2.5
182869-07-023-10-55	57-UPE-DO - ROOM 106 - DRINKING OUTLET	< 2.5	2.5
182869-07-023-10-56	58-UPE-DO - ROOM 107 - DRINKING OUTLET	< 2.5	2.5
182869-07-023-10-57	59-UPE-DO - ROOM 108 - DRINKING OUTLET	< 2.5	2.5
182869-07-023-10-58	60-UPE-DO - ROOM 109 - DRINKING OUTLET	8.0689	2.5
182869-07-023-10-59	61-UPE-DO - ROOM 123 - DRINKING OUTLET	< 2.5	2.5
182869-07-023-10-60	62-UPE-DO - ROOM 124 - DRINKING OUTLET	< 2.5	2.5
182869-07-023-10-61	63-UPE-DO - ROOM 111 - DRINKING OUTLET	< 2.5	2.5
182869-07-023-10-62	64-UPE-DO - ROOM 112 - DRINKING OUTLET	< 2.5	2.5
182869-07-023-10-63	65-UPE-DO - ROOM 113 - DRINKING OUTLET	4.8891	2.5
182869-07-023-10-64	66-UPE-F - MAIN OFFICE WORK ROOM - FAUCET	< 2.5	2.5
182869-07-023-10-65	67-UPE-EWC - MAIN OFFICE - ELECTRIC WATER COOLER	< 2.5	2.5
182869-07-023-10-66	68-UPE-EWC - CAFETERIA - ELECTRIC WATER COOLER	< 2.5	2.5



Results of Lead in Drinking Water

Client	<u>Spring-Ford Area School District</u>	Site Address	<u>Upper Providence Elementary - 833 S Lewis Rd, Royersford, PA 19468</u>	Sample Date	<u>1/19/2019</u>
Project #	<u>182869</u>			Sample Received Date	<u>1/23/2019</u>
Collected By	<u>Criterion Laboratories, Inc.</u>	Analyzed By	<u>Schwab, Andrew</u>	Sample Analysis Date(s)	<u>2/4/2019</u> <u>2/5/2019</u>

Sample Number	Location / Description	Lead (ppb)	Reporting Limit (ppb)
182869-07-023-10-67	69-UPE-EWC - BY NURSES OFFICE - ELECTRIC WATER COOLER HIGH	< 2.5	2.5
182869-07-023-10-68	70-UPE-EWC - BY NURSES OFFICE - ELECTRIC WATER COOLER LOW	< 2.5	2.5
182869-07-023-10-69	71-UPE-CF - MEDIA CENTER WORK ROOM - CLASSROOM FAUCET	14.9	2.5

Sample Count 69

James A. Wertz, CIH, Technical Director

EPA Action Limit is 15.0 ppb (parts per billion). Criterion Laboratories, Inc. bears no responsibility for sample collection activities of non-Criterion personnel. This report relates only to the samples reported above, and when reproduced, must be in its entirety. QC data associated with this sample set is within acceptable limits. Samples were received in good condition, unless otherwise noted.

Note: If your project number ends with an "R", it is a revised report and replaces the original document in full. Samples are analyzed by Criterion Laboratories, Inc. using EPA Method 200.9: Lead by Graphite Furnace Atomic Absorption (GFAA) and CLI Method 417.

Criterion Laboratories, Inc. (ID 100424) is accredited by the AIHA Laboratory Accreditation Programs (AIHA-LAP), LLC in the IHLAP; EMLAP and ELLAP accreditation programs for Polarized Light Microscopy (PLM), Phase Contrast Microscopy (PCM); Air-Direct Examination; and Airborne Dust, Paint, Settled Dust by Wipe and Soil for Fields of Testing as documented by the Scope of Accreditation Certificate and associated Scope. Additionally, Criterion Laboratories, Inc. is certified by the Center for Disease Control (CDC) Environmental Legionella Isolation Techniques Evaluation (ELITE) Program for the determination of Legionella in water by culture and holds accreditation from the National Voluntary Laboratory Accreditation Program (NVLAP ID 102046-0) for the determination of asbestos in bulk samples by Polarized Light Microscopy (PLM). This test report must not be used to claim product endorsement by NVLAP, NIST, AIHA or any agency of the US Government. Unless specifically listed as above, these test results are not covered under AIHA-LAP, LLC, 100424 accreditation.

THIS IS THE LAST PAGE OF THE REPORT